

Addendum No. 1

DATE: February 2, 2018

Project: WHA Job No. 2017-13
Stair Tower Repairs
200-2 Curtis Apartments

In accordance with documents prepared by: **Allen & Major Associates, Inc.**

TO: ALL PLANHOLDERS--BIDDERS--PROPOSERS--CONTRACTORS

This Addendum No. 1 forms part of and modifies the Construction Documents dated January, 2018. Acknowledge receipt of this Addendum in the space provided on the FORM FOR GENERAL BID. Failure to do so may subject the bidder to disqualification.

The attention of bidders submitting bids for the above subject project is called to the following addendum to the specifications and drawings. The items set forth herein, whether of omission, addition, substitution, or clarifications are all to be included in and form a part of the bid submitted.

This Addendum consists of ITEMS 1 and 2 which are hereby incorporated into the Bidding Documents:

REVISION TO SPECIFICATIONS:

ITEM NO. 1: Section 01.11.00 SUMMARY OF WORK; 11.2 TIME OF COMPLETION; paragraph A

DELETE: In accordance with Article 9 of General Conditions, the Work shall start in the Notice to Proceed and shall be complete within 154 consecutive calendar days.

INSERT: In accordance with Article 9 of General Conditions, the Work shall start on **May 1, 2018** and shall be complete within 154 consecutive calendar days.

PRE-BID CONFERENCE QUESTIONS/CLARIFICATIONS:

ITEM NO. 2: QUESTIONS/CLARIFICATIONS:

1. Question: According to drawing S-4.0 Notes 1. Top surface of stair (A. Remove existing paint @ stair landing, tread & riser to Steel. Can another method be used as well? Instead of SSPC-SP6 Commercial Blast Cleaning, Can SSPC-SP3 Power Tool Cleaning be used?
Response: No
2. Question: According to drawing S-4.0 Notes 1. Top surface of stair (A. Remove existing paint @ stair landing, tread & riser to Steel. Do you want the steel down to bare steel?
Response: Yes

All other terms and conditions of these contract documents remain unchanged.

**FAILURE TO ACKNOWLEDGE THIS ADDENDUM ON YOUR BID FORMS
MAY BE CAUSE FOR BID REJECTION.**

END OF ADDENDUM NO. 1